



* If Ductile Iron Pipe (Type "G") is used within the trench, granular bedding and backfill may be used in place of concrete in accordance with 603.06 and 603.10.

NOTE: MINIMUM REQUIREMENT FOR TWO (2) PIPES IN ONE (1) TRENCH. (TO BE USED ONLY WITH SPECIAL PERMISSION AS AUTHORIZED BY M.S.D.)

Class "C" Concrete
(Dry Mix is Permissible)

THE
METROPOLITAN SEWER DISTRICT
OF
GREATER CINCINNATI
**SPECIAL DETAIL FOR LAYING
TWO BUILDING SEWERS
IN ONE TRENCH**

NO SCALE

DATE: AUG., 2006

APPROVED:

SEWERS CHIEF ENGINEER

S.N.

ACC. NO. 49052