
Site Plan Checklist

- Specify tap material as 6" PVC SDR-35 @ 2% min slope.
- Add invert elevation at tap connection point to the sewer main.
- Show cleanout at ROW or easement line.
- Add rim elevation of upstream manhole.
- Add note: "If lowest level elevation is below rim elevation of upstream manhole, then tap must include backflow prevention or be pumped to gravity."
- Show existing sewers and associated easements on the site plan.
- Include lowest level elevation of the building.